



Catherine B. Templeton, Director

Promoting and protecting the health of the public and the environment

PUBLIC NOTICE

Notice # 04175-01

March 27, 2014

This notice is to inform the public that the S. C. Department of Health and Environmental Control (Agency) is taking public comments on a Corrective Action Plan (CAP). This CAP addresses the cleanup of soil and groundwater contamination at the facility listed below. The contamination was caused by petroleum products that were released from the underground storage tank system at this facility.

FACILITY: Sunoco 681 (former Speedway 611), 2350 E. North St, Greenville, SC

APPLICANT: Cardno ATC, 4020 Old Pineville Rd., Charlotte, NC on behalf of Speedway, LLC,
500 Speedway Dr., Enon, OH

SUMMARY OF CAP: Petroleum and petroleum byproducts naturally break down over time through chemical, physical, and biological processes. These processes are called natural attenuation. Cardno ATC has submitted a CAP proposing the use of the following technologies in addition to natural attenuation to clean up the contamination.

- Surfactant Injection and Aggressive Fluid Vapor Recovery: Surfactant is injected to increase the mobility of the petroleum contamination. The surfactant and contamination are then recovered through aggressive fluid vapor recovery events, where a high-pressure vacuum is attached to recovery wells to remove petroleum vapors, contaminated groundwater, and the petroleum product.

PUBLIC COMMENT PERIOD DEADLINE: The **deadline** for submitting written comments is **5 PM April 27, 2014**. Any interested person(s) may submit written comments concerning the cleanup to the Project Manager listed below. Please bring this notice to the attention of persons whom you know will be interested in this matter. Where there is a significant degree of public interest, the Agency will hold a public hearing.

Sonya T. Utz
SCDHEC - UST Management Division
2600 Bull Street
Columbia SC 29201
803-898-0634

CONTACT INFORMATION: For additional information, please call the Project Manager listed above. To view a copy of the CAP, contact the Freedom of Information Office at 803-898-3882.

Section 280.67 of the S.C. Underground Storage Tank Control Regulations (R.61-92) requires that any CAP prepared to meet the requirements of 280.66 be placed on notice for public comment.